



**NOTES:**

1. HYDRANTS SHALL BE ANY APPROVED MODEL FROM THE APPROVED MATERIALS LIST.
2. PAINT SHALL BE COMPRISED OF ONE COAT OF SHERWIN-WILLIAMS "KEM KROMIK" RED OXIDE UNIVERSAL METAL PRIMER AND TWO COATS OF SHERWIN-WILLIAMS "INDUSTRIAL ENAMEL" B54 E39 IN SAFETY ORANGE.
3. ALL JOINTS TO BE RESTRAINED USING APPROVED THRUST RESTRAINT WITH THRUST BLOCK ADDED FOR TAPPING SLEEVE.
4. ALL FITTINGS IN CONTACT W/CONCRETE SHALL BE WRAPPED IN PLASTIC. HYDRANT DRAIN HOLES TO REMAIN OPEN TO DRAIN ROCK & OPERATIONAL.
5. MIN. 4 CU. FT. OF 1 1/2"-3/4" CLEAN DRAIN ROCK SHALL BE PLACED AROUND SHOE UP TO A MIN. OF 6" ABOVE DRAIN OUTLETS.
6. WHERE PLANTER STRIP EXISTS, HYDRANT SHALL BE PLACED SO FRONT PORT IS MINIMUM 36" BEHIND FACE OF CURB. PLACE 4'x 4'x 6" CONCRETE APRON AROUND HYDRANT.
7. NO EXTENSIONS ALLOWED.
8. WHERE INTEGRAL CURB & S/W EXISTS, HYDRANT SHALL BE PLACED AT BACK OF SIDEWALK, OR AS DIRECTED BY CANBY UTILITY.
9. HYDRANT BURY SHALL BE MEASURED FROM FINISHED GRADE TO BOTTOM OF CONNECTING PIPE.
10. HYDRANT VALVE SHALL BE AN APPROVED RESILIENT WEDGE GATE VALVE.
11. HYDRANT MUST INCLUDE STORZ ADAPTER.

<b>STANDARD FIRE HYDRANT ASSEMBLY</b>	
	DATE: <b>9/12/2023</b>
	DRAWING NO. <b>004</b>