



**Canby Fire District**  
221 S. Pine Street  
Canby, Oregon 97013  
(503) 263-4281

## Fire Protection Systems Inspection, Testing, and Maintenance Schedules

### **Fire Extinguisher Testing and Inspection Schedule**

**NFPA 10 (Standard for Portable Fire Extinguishers)**. Considered the first line of defense, portable fire extinguishers need to be inspected on a routine basis. Many people do not know that fire extinguishers must also be visually inspected monthly. The property owner is permitted to conduct monthly visual inspections. Each tag attached to the fire extinguisher will have a monthly inspection area for the date of inspection and initials of person performing monthly check.



- **Monthly:** Visual inspection (by owner).
- **Annually:** Inspection and maintenance by a fire protection company required.
- **5-year:** Carbon dioxide, wet chemical, and water fire extinguishers must be hydrotested.
- **3-year:** AFFF and FFFP foam extinguishers require internal examination.
- **6-year:** Dry chemical extinguishers require internal examination.
- **12-year:** Dry chemical and halogenated extinguishers must be hydrotested.

***Your facility may have additional systems in need of certification by a fire protection company. Discuss your needs with your fire protection contractor or contact Canby Fire District for more information.***

***To gain additional information, or for questions,  
please contact our Fire Inspector at: (503) 263-4281.***

*Canby Fire District is committed to creating safer communities through prevention, preparedness, and effective fire and medical emergency response.*